

APPROVAL FOR CONSTRUCTION

N.H. DEPARTMENT OF ENVIRONMENTAL SERVICES
WATER SUPPLY & POLLUTION CONTROL DIVISION
P.O. BOX 95, 6 HAZEN DRIVE, CONCORD, NH 03301

THE PLANS AND SPECIFICATIONS FOR SEWAGE OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

OWNER: TAFT, D TAFT, DOROTHY
PO BOX 563
EXETER, NH 03833

APPROVAL NO. 171910

Lot Numbers: 35673-A
Subd. Appvl. No.: STANLEY SIUDAK
Subd. Name: 0000003BR
Type of System: 000450GPD

COPY OF PLAN & APPROVAL SENT TO: HEALTH OFFICER
TOWN HALL
NEWMARKET, NH 03857

Town/City Location: NEWMARKET

Street Location: BALD HILL ROAD

BY APPLICANT: PERMIT NO. 000000348

STOCKTON SERVICES
PO BOX 1306
HAMPTON, NH, 03842

Subsurface waste disposal systems must be operated and maintained in a manner so as to prevent nuisance or health hazard due to system failure. (RSA 149-E:3-b)

It is unlawful to discharge any hazardous chemicals or substances into subsurface waste disposal systems. Included are paints, thinners, gasoline and chlorinated hydrocarbon solvents such as TCE, sometimes used to clean failed septic systems and auto parts. (WS 410.05)

ADVISE YOUR CONTRACTOR OF REQUIRED CHANGES
IN PLANS AS INDICATED BY BELOW CONDITIONS

NO FOUNDATION DRAINS WITHIN 25' OF THE SEPTIC TANK AND 35' OF THE LEACHFIELD. 7' TO IMERMEABLE.

Kim Margolies
KIM MARGOLIES

Approved this date: 03/28/89 By: W00047479 N.H. Water Supply & Pollution Control Division Staff

APPLICANT'S

PERC TEST DATE: 4/29/87

DEPTH OF HOLE: 30"

RATE OF PERC: * 5 MIN/IN BY PARKER SURVEY (SEE NOTE A)

DESIGN LOADING: 3 BEDROOMS

AREA REQUIRED: 646 SQ. FT.

PROPOSED SYSTEM: 20 x 40 FOR 800 SQ. FT. AREA PROVIDED

PLAN OF PROPOSED
SEPTIC SYSTEM

REVIEWED AND APPROVED
IN ACCORDANCE WITH THE
REQUIREMENTS OF THE
NEW HAMPSHIRE
WATER SUPPLY & POLLUTION
CONTROL COMMISSION



Signed *Kim Margolies*
Date 3-28-89

LOCUS: LOT 3 BALD HILL ROAD
NEWMARKET, N.H. 171910

ADVISE YOUR CONTRACTOR
OF REQUIRED CHANGES IN
PLANS AS INDICATED ON THIS
CONDITIONAL APPROVAL.

OWNER: DONALD & DOROTHY TAFT
C/O GORSKI ASSOC
PO BOX 563, EXETER, NH 03833

APPLICANT: STOCKTON SERVICES
PO BOX 1306
HAMPTON, N.H. 03842
DESIGNER PERMIT #348



DATE: 2/17/89 REVISED 3/20/89

APPROVAL: 109

